



Burlington, WA Corporate Laboratory (a)
1626 S Walnut St. - Burlington, WA 96233 - 800.755.9295 • 360.757.1460

Bellingham, WA Microbiology (b)
805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
5150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802

Corvallis, OR Microbiology/Chemistry (d)
540 SW Third Street - Corvallis, OR 97333 - 541.753.4546

Bend, OR Microbiology (e)
20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
12950 NW Main St.
Banks, OR 97106

Reference Number: 16-13487
Project: BES

System Name:
System ID Number:
DWP Source Number:
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/9/2016
Report Date: 6/28/2016
Approved By: apj
Authorized by:

Colin P. O'Dwyer
Chemist/Microbiologist

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30685	6/8/2016	DW01 BES GYM	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30686	6/8/2016	DW 02 BES GYM	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30687	6/8/2016	DW MUSIC	1030	LEAD	0.0032	mg/L	0.015	0.001	200.8	4072	
16_30688	6/8/2016	DW OFFICE	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
16_30689	6/8/2016	DW 1 LIB. F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30690	6/8/2016	DW 2 LIB. F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30691	6/8/2016	DW RM 104	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30692	6/8/2016	DW RM 105	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30693	6/8/2016	DW RM 106	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30694	6/8/2016	DW RM 107	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30695	6/8/2016	DW RM 108	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30696	6/8/2016	DW RM 109	1030	LEAD	0.0013	mg/L	0.015	0.001	200.8	4072	
16_30697	6/8/2016	DW RM 110	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30698	6/8/2016	DW RM 111	1030	LEAD	0.0025	mg/L	0.015	0.001	200.8	4072	
16_30699	6/8/2016	DW RM 112	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30700	6/8/2016	DW RM 101	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30701	6/8/2016	DW RM 102	1030	LEAD	0.0021	mg/L	0.015	0.001	200.8	4072	

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

RL (Reporting Level): indicates the minimum reporting level.

AL (Federal Action Levels) are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence J Henderson at the above phone number.



INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30702	6/8/2016	DW RM 103	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30703	6/8/2016	DW F 1 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30704	6/8/2016	DW F 2 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30705	6/8/2016	RM 204	1030	LEAD	0.0024	mg/L	0.015	0.001	200.8	4072	
16_30706	6/8/2016	RM 205	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30707	6/8/2016	RM 206	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
16_30708	6/8/2016	RM 207	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
16_30709	6/8/2016	RM 208	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30710	6/8/2016	RM 209	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30711	6/8/2016	RM 210	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30712	6/8/2016	RM 211	1030	LEAD	0.0016	mg/L	0.015	0.001	200.8	4072	
16_30713	6/8/2016	RM 212	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30714	6/8/2016	RM 213	1030	LEAD	0.0023	mg/L	0.015	0.001	200.8	4072	
16_30715	6/8/2016	RM 214	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
16_30716	6/8/2016	RM 201	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30717	6/8/2016	RM 202	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30718	6/8/2016	RM 203	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

IOC (Reporting Level): indicates the minimum reporting level.

L Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.662.7802
 Corvallis, OR Microbiology/Chemistry (d)
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.635.8425



INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
 12950 NW Main St.
 Banks, OR 97106

Reference Number: 16-13487
 Project: BES

System Name:
 System ID Number:
 DWP Source Number:
 Multiple Sources:
 Sample Type: D - Drinking Water
 Sample Purpose: Investigative or Other
 County:

Analyst: bj
 Date Received: 6/9/2016
 Report Date: 6/28/2016
 Approved By: anp
 Authorized by:

Colin P O'Dwyer
 Chemist/Microbiologist

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30685	6/8/2016	DW01 BES GYM	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30686	6/8/2016	DW 02 BES GYM	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30687	6/8/2016	DW MUSIC	1030	LEAD	0.0032	mg/L	0.015	0.001	200.8	4072	
16_30688	6/8/2016	DW OFFICE	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
16_30689	6/8/2016	DW 1 LIB. F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30690	6/8/2016	DW 2 LIB. F	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30691	6/8/2016	DW RM 104	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30692	6/8/2016	DW RM 105	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30693	6/8/2016	DW RM 106	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30694	6/8/2016	DW RM 107	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30695	6/8/2016	DW RM 108	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30696	6/8/2016	DW RM 109	1030	LEAD	0.0013	mg/L	0.015	0.001	200.8	4072	
16_30697	6/8/2016	DW RM 110	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30698	6/8/2016	DW RM 111	1030	LEAD	0.0025	mg/L	0.015	0.001	200.8	4072	
16_30699	6/8/2016	DW RM 112	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30700	6/8/2016	DW RM 101	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30701	6/8/2016	DW RM 102	1030	LEAD	0.0021	mg/L	0.015	0.001	200.8	4072	

IOC (Reporting Level): Indicates the minimum reporting level.
 Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

*Not Detected: indicates that the compound was not detected above the Reporting Level (RL).



Reference Number: 16-13487

Report Date: 6/28/16

Page 2 of 2

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Sample Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
3_30702	6/8/2016	DW RM 103	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30703	6/8/2016	DW F 1 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30704	6/8/2016	DW F 2 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30705	6/8/2016	RM 204	1030	LEAD	0.0024	mg/L	0.015	0.001	200.8	4072	
3_30706	6/8/2016	RM 205	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30707	6/8/2016	RM 206	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
3_30708	6/8/2016	RM 207	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
3_30709	6/8/2016	RM 208	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30710	6/8/2016	RM 209	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30711	6/8/2016	RM 210	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30712	6/8/2016	RM 211	1030	LEAD	0.0016	mg/L	0.015	0.001	200.8	4072	
3_30713	6/8/2016	RM 212	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30714	6/8/2016	RM 213	1030	LEAD	0.0023	mg/L	0.015	0.001	200.8	4072	
3_30715	6/8/2016	RM 214	1030	LEAD	0.0011	mg/L	0.015	0.001	200.8	4072	
3_30716	6/8/2016	RM 201	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30717	6/8/2016	RM 202	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
3_30718	6/8/2016	RM 203	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

L (Reporting Level): indicates the minimum reporting level.

Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.5295 - 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7602
 Corvallis, OR Microbiology/Chemistry (d)
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
 12950 NW Main St.
 Banks, OR 97106

Reference Number: 16-13500
 Project: BMS

System Name:
 System ID Number:
 DWP Source Number:
 Multiple Sources:
 Sample Type: D - Drinking Water
 Sample Purpose: Investigative or Other
 County:

Analyst:.mvp
 Date Received: 6/9/2016
 Report Date: 6/22/2016
 Approved By: bj
 Authorized by:

Thanh B Phan
 Thanh B Phan
 Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30742	6/8/2016	DW F GYM	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30743	6/8/2016	DW MUSIC	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30744	6/8/2016	DW SCIENCE	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30745	6/8/2016	DW RM 115	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30746	6/8/2016	DW RM 116	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30747	6/8/2016	DW RM 120	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30748	6/8/2016	DW F 1 DS	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30749	6/8/2016	DW F 2 DS	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30750	6/8/2016	DW RM 201	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30751	6/8/2016	DW RM 216	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30752	6/8/2016	DW RM 215	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30753	6/8/2016	DW F 1 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30754	6/8/2016	DW F 2 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30755	6/8/2016	DW RM 212	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30756	6/8/2016	DW RM 208	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30757	6/8/2016	DW RM 209	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30758	6/8/2016	DW RM 211	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

RL (Reporting Level): indicates the minimum reporting level.

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Reference Number: 16-13500

Report Date: 6/22/16

Page 2 of 2

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30759	6/8/2016	DW RM 215	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

IOC

L (Reporting Level): indicates the minimum reporting level.
 L Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.
 D (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA Corporate Laboratory (a)
 1620 S Walnut St - Burlington, WA 98233 - 800.755.9295 - 360.757.1400
 Bellingham, WA Microbiology (b)
 805 Orchard Dr Ste 4 - Bellingham, WA 98225 - 360.715.1212

Portland, OR Microbiology/Chemistry (c)
 9150 SW Pioneer Ct Ste W - Wilsonville, OR 97070 - 503.682.7802
 Corvallis, OR Microbiology/Chemistry (d)
 540 SW Third Street - Corvallis, OR 97333 - 541.753.4946
 Bend, OR Microbiology (e)
 20332 Empire Blvd Ste 4 - Bend, OR 97701 - 541.639.8425



INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
 12950 NW Main St.
 Banks, OR 97106

Reference Number: **16-13500**
 Project: BMS

System Name:
 System ID Number:
 DWP Source Number:
 Multiple Sources:
 Sample Type: D - Drinking Water
 Sample Purpose: Investigative or Other
 County:

Analyst: mvp
 Date Received: 6/9/2016
 Report Date: 6/22/2016
 Approved By: bj
 Authorized by:

Thanh B Phan
 Lab Manager, Portland

Lab Number	Date Collected	Site / Location	EPA #	Analyte Name	Result	Units	AL	RL	METHOD	Lab	Comments
16_30742	6/8/2016	DW F GYM	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30743	6/8/2016	DW MUSIC	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30744	6/8/2016	DW SCIENCE	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30745	6/8/2016	DW RM 115	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30746	6/8/2016	DW RM 116	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30747	6/8/2016	DW RM 120	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30748	6/8/2016	DW F 1 DS	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30749	6/8/2016	DW F 2 DS	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30750	6/8/2016	DW RM 201	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30751	6/8/2016	DW RM 216	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30752	6/8/2016	DW RM 215	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30753	6/8/2016	DW F 1 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30754	6/8/2016	DW F 2 UP	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30755	6/8/2016	DW RM 212	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30756	6/8/2016	DW RM 208	1030	LEAD	0.001	mg/L	0.015	0.001	200.8	4072	
16_30757	6/8/2016	DW RM 209	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	
16_30758	6/8/2016	DW RM 211	1030	LEAD	ND	mg/L	0.015	0.001	200.8	4072	

NC

RL (Reporting Level): indicates the minimum reporting level.

AL (Federal Action Levels) are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Reporting Level (RL).

These test results meet all the requirements of NELAP, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 96233	806.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	605 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4945



FL NELAP E871040


INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
 12950 NW Main St.
 Banks, OR 97106

Reference Number: 16-13477
 Project: BHS

System Name:
 System ID Number:
 DOH Source Number:
 Multiple Sources:
 Sample Type: D - Drinking Water
 Sample Purpose: Investigative or Other
 County:

Analyst: bj
 Date Received: 6/9/2016
 Report Date: 6/28/2016
 Approved By: anp
 Authorized By:


 Colin P O'Dwyer
 Chemist/Mircobiologist

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
4072-30666	6/8/2016	DIST OFFICE	9	LEAD	0.0012	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30667	6/8/2016	HS WORK RM	9	LEAD	0.0065	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30668	6/8/2016	HS F OFFICE	9	LEAD	0.0017	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30669	6/8/2016	HS AG KITCHEN	9	LEAD	0.0128	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30670	6/8/2016	HS MUSIC	9	LEAD	0.0129	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30671	6/8/2016	HS GYM	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30672	6/8/2016	HS CAFE	9	LEAD	0.0101	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30673	6/8/2016	HS GYM HALL	9	LEAD	0.0020	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30674	6/8/2016	HS FRESH HALL	9	LEAD	0.0157	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30675	6/8/2016	HS ICE	9	LEAD	0.0018	mg/L	0.015	0.001	200.8	a	6/27/16	

NC

SRL (Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

AL Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946



FL NELAP E871040
Page 1 of 1

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
12950 NW Main St.
Banks, OR 97106

Reference Number: 16-13477
Project: BHS

System Name:
System ID Number:
DOH Source Number:
Multiple Sources:
Sample Type: D - Drinking Water
Sample Purpose: Investigative or Other
County:

Analyst: bj
Date Received: 6/9/2016
Report Date: 6/28/2016
Approved By: anp
Authorized By:

Colin P O'Dwyer
Chemist/Mircobiologist

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
4072-30666	6/8/2016	DIST OFFICE	9	LEAD	0.0012	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30667	6/8/2016	HS WORK RM	9	LEAD	0.0065	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30668	6/8/2016	HS F OFFICE	9	LEAD	0.0017	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30669	6/8/2016	HS AG KITCHEN	9	LEAD	0.0128	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30670	6/8/2016	HS MUSIC	9	LEAD	0.0129	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30671	6/8/2016	HS GYM	9	LEAD	ND	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30672	6/8/2016	HS CAFE	9	LEAD	0.0101	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30673	6/8/2016	HS GYM HALL	9	LEAD	0.0020	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30674	6/8/2016	HS FRESH HALL	9	LEAD	0.0157	mg/L	0.015	0.001	200.8	a	6/27/16	
4072-30675	6/8/2016	HS ICE	9	LEAD	0.0018	mg/L	0.015	0.001	200.8	a	6/27/16	

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
AL: Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.
ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9285 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.662.7802
Corvallis, OR	Microbiology (d)	540 SW Thirti Street	Corvallis, OR 97333	541.753.4946



FL NELAP E871040

Page 1 of 1

INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Banks School District
 12950 NW Main St.
 Banks, OR 97106

Reference Number: 16-13473

Project: BHS

System Name:
 System ID Number:
 DOH Source Number:
 Multiple Sources:
 Sample Type:
 Sample Purpose: Investigative or Other
 County:

Analyst: bj
 Date Received: 6/9/2016
 Report Date: 6/28/2016
 Approved By: anp
 Authorized By:

Colin P O'Dwyer
 Chemist/Mircobiologist

Lab Number	Date Collected	Site / Location	PRM #	Analyte Name	Result	Units	AL	SRL	METHOD	Lab	Analyzed	Comments
46-30638	6/8/2016	HS TAM OFFICE	9	LEAD	0.0117	mg/L	0.015	0.001	200.8	a	6/22/16	

AL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper under the Lead and Copper Rule for public water systems. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.